



Empowering you to work smarter

NX1 NX1V Nexus Digital Manifold Gauge User Manual



NAVAC Inc.
www.NavacGlobal.com
Tel/Fax: +1 877 MY-NAVAC
877 696 2822
MADE IN PRC



Compatible with *MyNAVAC™* APP



Failure to follow warnings could result in death or serious injury.

**SAVE THIS MANUAL
FOR FUTURE REFERENCE**

CONTENTS

Safety Information	01
NX1 Nexus Digital Manifold Gauge	02
Product Overview	02
Technical Specification	02
Indicator Light	03
Icons	03
Auto-Shutdown	03
Function introduction	03
Bluetooth Pairing	03
Parameter Setting	04
Manifold Gauge Mode	04
Leak Test Mode	06
Evacuation Mode	07
Vacuum Attenuation Mode	08
Exploded View & Spare Parts List	09
APP Refrigerant Update	10
NMV1S Premium Micron Vacuum Gauge	12
Instrument Overview	12
Function Introduction	12
Technical Specifications	13
Display Range	13
Automatic Shutdown	13
Operation	14
Warning	15
Smart Thermometer	17
Product Overview	17
Technical Specification	17
Screen Display	17
Indicator Light	18
Alarm	18
Bluetooth Connection	18
Automatic Shutdown	18
Key Function	18
Exploded View & Spare Parts List	19
Guide for App Download & Connection	20
Log In	20
Page Introduction	21
Basic Functions	22

This series of products are app products, which can be connected with NAVAC'S APP "my NAVAC". Please refer to the end of the manual for downloading the connection guide.

Safety Information

Use the instrument only as specified in this manual. Otherwise, the protection provided by the instrument may be impaired.

To avoid personal injury or death, follow these guidelines:

- Most governments and legal authorities require that HVAC technicians be trained and certified in the safe and proper operation of HVAC tools, such as this instrument. Since this tool may be connected to many types of equipment through a limitless combination of hoses and fittings, proper training is the most important element of using this tool safely.
- Read the entire Users Manual before using the instrument.
- Use the instrument only as described in the Users Manual, otherwise the protection provided by the equipment may be impaired.
- Do not use the instrument if it is damaged. Before you use the instrument, inspect the case. Look for cracks or loose components.
- The instrument contains no internal user-serviceable parts. Do not open the instrument.
- Do not use the instrument if it operates abnormally. Protection may be impaired. When in doubt, have the instrument serviced.
- Do not operate the instrument around explosive gas, vapor, or dust.
- The refrigerant database in this unit may include refrigerants classified as flammable. If such refrigerants are selected, the operator may need additional certifications and/or training. Consult your government and legal authority and comply fully with all requirements.
- Always wear eye and skin protection when working with refrigerants. Escaping refrigerant vapors will present a freezing danger. Do not direct refrigerant vapors venting from hoses towards the skin.
- Do not allow pressures beyond the specifications listed in this manual.

Warning

This product operates under high pressure. Follow all safety guidelines regarding refrigerant handling including wearing Personal Protective Equipment such as safety glasses, and gloves.

Product Overview



Technical Specification

Model	NX1	NX1V
Accessory	2 Temperature Probes, Charging Cable, Carry Case	NMV1S Micron Gauge in additional to the NX1 Kit
72 Refrigerant Types	R-11, R-113, R-114, R-115, R-116, R-12, R-123, R-1233zd, R-1234yf, R-1234ze, R-124, R-125, R-13, R-134a, R-22, R-23, R-236fa, R-245fa, R-290, R-32, R-401A, R-401B, R-402A, R-402B, R-403B, R-404A, R-406A, R-407A, R-407B, R-407C, R-408A, R-409A, R-410A, R-413A, R-414A, R-414B, R-416A, R-417A, R-417C, R-420A, R-421A, R-421B, R-422A, R-422B, R-422C, R-422D, R-424A, R-427A, R-428A, R-434A, R-437A, R-438A, R-448A, R-449A, R-450A, R-452A, R-452B, R-453A, R-454B, R-458A, R-500, R-501, R-502, R-503, R-507A, R-508B, R-513A, R-600, R-600A, R-601, R-601A, R-744* Firmware can be updated at NAVAC website or with MyNAVAC™ App *Maximum pressure: 600 Psi (4200 kPa)	
Max. Over Pressure	1015.3 psi (70 bar)	
Pressure Unit	bar, Mpa, -Kpa, psi, kgf/cm ²	
Vacuum Unit	Pa, micron, mBar, mmHg	
Temperature Unit	°C, °F	
Pressure Scale	-1-50 bar, -0.1-5 Mpa, -100-5000Kpa, -14.5-725psi, -1.02-51kgf/cm ²	
Resolution	0.01 bar, 0.001Mpa, 1Kpa, 0.1psi, 0.01kgf/cm ²	
Temperature Resolution	32-104°F (0-40°C)	
Battery	3000 mAh Li-polymer	
Connection	7/16" UNF	
Sensor	Digital Sensor	
Unit Dimension	7.7"x2.8"x9"	
Unit Weight	27 lbs	

Indicator Light

Always on/ Flashing	Power on	Power off
	Bluetooth is not connected	/
	Bluetooth is connected	/
	Device power is low	Charging
	/	Fully charged

Icons

- : Power display;
- : Flashing - low battery alarm,
 T1 - low battery of Thermometer -LP;
 T2 - low battery of Thermometer -HP;
 VG - low battery of Vacuum Gauge;
- : Bluetooth connection identification; 0 / 1 / 2 / 3 / 4 indicates the number of Bluetooth connections, indicates no connection.

Auto-Shutdown

1. Pressure value stays at 0, no action on buttons, automatic shutdown after 30 minutes;
2. Pressure sensor malfunction, no action on buttons, automatic shutdown after 10 minutes;
3. Low battery, automatic shutdown.

Function Introduction

- On/Off key:** Press and hold for 1s to start the machine, press and hold for 2s to shut it down;
- Mode Selection Key:** Manifold Gauge Mode, Leak Test Mode, Evacuation Mode and Decay Test Mode;
- Setting Key:** Press and hold for 2s to enter the parameter setting;
- Up Key:** Moves the parameter upwards;
- Down Key:** Moves the parameter downwards;
- Confirm Key:** Setup interface to confirm parameters; Start/Stop in Leak Test mode.

Calibration

Press and hold for 2 seconds to zero out the pressure.

Bluetooth Pairing

1. To pair the low pressure side, press and hold **ENTER** + **▲** for 3 seconds.
2. To pair the high pressure side, press and hold **ENTER** + **▼** for 3 seconds.
3. To pair the vacuum gauge, click "Mode" button to switch NX1 to Evacuation Mode, then press and hold **ENTER** + **▼** for 3 seconds.

In Evacuation Mode, Press and hold **ENTER** + **▼** for 3 seconds.

Parameter Setting

In Manifold Gauge mode, Leak Test mode, Evacuation mode, press and hold "**SET**" key for 2s, enter the parameter setting interface, press "**▼**" or "**▲**" cycle and select the parameter content (refrigerant setting, press and hold to scroll through refrigerant type), press "**ENTER**" will switch to the next parameter setting, when all the parameter setting is completed, the screen will return to the original interface.

Factory Refrigerant Type: R-11, R-12, R-13, R-22..... (Total 72 types)

Pressure unit: MPa, bar, kgf/cm2, psi, Kpa.


Temperature unit: °C, °F

Vacuum unit: Pa, micron, mBar, mmHg

Sound: ON/OFF

Backlight: **1min/3min/10 min/OFF** (the number indicates that the backlight turns on for a few minutes after operation without buttons, and OFF indicates that it turns off)

Manifold Gauge Mode



Pressure values at the high and low pressure ends are displayed as gauge pressure.
(Gauge pressure = measured pressure - atmospheric pressure)

VSAT: Vapor saturation temperature.

LSAT: Liquid saturation temperature.

T1 SLT: Suction line temperature.


T2 LLT: Liquid line temperature.

SH: Superheat value SH = T1 SLT-VSAT.


SC: Subcooling value SC = LSAT-T2 LLT.

T1 -T2: temperature difference.

Dial scale (in Mpa):




When the pressure value is less than 0, the pressure unit automatically switches to inHg.



Leak Test Mode

Screen Display Introduction



Operation


Note: the system needs to be connected to the **high side** of the manifold gauge.

- (1) Press the "**ENTER**" (show button as original) key to start the leak test. The bottom of the screen displays "START", the right side of the screen displays the real-time pressure value, the leak test timer starts, and the value of "d P" starts calculating.
- (2) Press the "**ENTER**" key again, the bottom of the screen shows "END", the leak test timer stops and the final pressure difference is displayed at "d P";
- (3) Press the "**ENTER**" key again to **Reset**.



Evacuation Mode

Screen Display Introduction



Evacuation value display range is 0-9999;
 10000-19999 micron is displayed as "1E4";
 20000-29999 micron is displayed as "2E4";
 2:30000 micron is displayed as"....".



Vacuum Gauge Bluetooth Pairing


The first time you connect the vacuum gauge NMV1S, you need to do the Bluetooth pairing manually:

At this time, the Bluetooth logo "CONNECT NMV1S" of the digital display meter is flashing, long press "**ENTER** + **▼**" for more than 3 seconds to enter the Bluetooth pairing interface of the vacuum gauge, "-----" is lit in sequence, indicating that the device is searching for Bluetooth, if the screen shows "b7c", indicating that the Bluetooth has been successfully connected, and then it will return to the interface of the **Evacuation Mode** in 2s, and the Bluetooth logo "CONNECT NMV1S" will disappear.

Notes:

- (1) When in Bluetooth pairing, no other operation can be performed for 30 seconds.
- (2) The digital gauge will automatically connect to the paired vacuum gauge when it is in vacuum mode.

Decay Test Mode



Vacuum Attenuation Mode Parameter Settings


Long press the "SET" key for two seconds to enter the vacuum attenuation parameter setting interface. There are 4 kinds of setting parameters, the order are: vacuum unit, "TARGET", "DECAY" and "TIMER". When the parameter is selected, the corresponding icon and value will flash, short press the "▼" or "▲" key to downward or up to select the value cyclically, press the "ENTER" key to lock and save, the parameter will display constant light and automatically switch to the next parameter setting.

Function

When connected to the vacuum gauge, the digital display will receive the "TARGET", "DECAY" and "TIMER" setting values from the vacuum gauge and display them in the corresponding positions on the screen.

- (1) Start vacuum extraction, when the vacuum level of the measuring device is less than the "Target" setting;
- (2) The vacuum pumping is stopped and when the vacuum value is greater than the "Target", the vacuum decay mode is entered and the "TIMER" starts timing;
- (3) If the vacuum value does not exceed the setting value of "DECAY" within the time set by "TIMER", it will display "PASS" (Pressure Holding Successful), otherwise it will display "FAIL".

Exploded View



Spare Parts List

No.	Item	Qty
1	Knob Cover	2
2	Knob	2
3	Top Cover	1
4	PC Transparent Plate	1
5	Button	2
6	PCBA	1
7	Battery Plate	1
8	Li-ion Battery	1
9	Retainer Block	1
10	Bottom Cover	1
11	Rubber Plug	1
12	Hook Assembly	1
13	Wire Bond	2
14	Sensor Assembly	2
15	O-ring	2
16	Valve Body Assembly	1

NMV1S Overview




Function Introduction

1. Operation Key

- 1.1. : Power on / off key. Press 1 second to turn on, press 2 seconds to turn off.
- 1.2. : Down key. In setting mode, adjust settings. In decay testing mode, set timer and leakage rate.
- 1.3. : Up key. In setting mode, adjust settings. In decay testing mode, set timer and leakage rate.
- 1.4. : Parameter setting key. Interface display "o o o o o" press and hold for 2s to enter the parameter setting interface.

2. Screen Display

- 2.1. SET : Parameter setting mode.
- 2.2. : Power indicator.
- 2.3. : Bluetooth connection indicator;
0 / 1 / indicates the number of Bluetooth connections.
- 2.4. Evac Target: minimum target vacuum;
(Vacuum value expected to be reached by the evacuation system)
- 2.5. Decayed target: the maximum target vacuum degree which should be greater than the target vacuum value;
- 2.6. Decay time: pressure maintaining time. (Triggered only when the minimum and maximum target vacuum are not setting to "off");
- 2.7. Decay test: enter the decay testing procedure;
- 2.8. Rate: leakage rate, leakage rate unit: / min.



Technical Specifications

Model	NMV1S
Location	Indoor use
Altitude	≤5000m
Humidity	≤75% R.H.
Intended Use	Pressure Measurement
Maximum Overload Pressure	50 psi / 3.4 bar
Range	0~25000 microns, 0~3333.3 Pa, 0~33.3 mBar, 0~25 mmHg.
Resolution	0.01 micron (<10 microns), 0.01Pa (<10 Pa), 0.001 mBar, 0.001 mmHg
Accuracy	50~1000 microns:± 5% of reading(at 68 F)
Operating Temperature	32~104 F (0~40℃)
Battery	2000 mAh Li-polymer
Charge Parameter	Max. 5V 2A
Unit	Pa, mBar, mmHg, microns
Connections	1/4" SAE
Sensor	Pirani sensor
Weight	6.2 oz

Indicator Light:

	Indicate Low Battery
	Powered on, Bluetooth is not connected
	Bluetooth is connected

Display Range

Vacuum display range for vacuum pumping: 0-25000 microns (3333.3 Pa, 33.3 mbar, 25 mmHg). Over range display "o o o o o".

Automatic Shutdown

When the vacuum gauge has a reading displayed, the automatic shutdown program will not be triggered for 2 hours; The automatic shutdown program will be triggered only when the interface displays atmospheric pressure "----", and without any operation on the interface.

Operation

1. Start, Shut off

Press 1 second to turn on, press 2 seconds to turn off.

2. Parameter Setting Interface


2.1. The vacuum display area displays "----", long press 2 seconds to enter the parameter setting interface.

2.2. Vacuum unit setting:

Press , to select unit, press to lock and switch to next parameter setting.

2.3. "Evac target" setting: (minimum target vacuum)

Press , to select the flashing value, then press to lock and stay on, then switch to the next "delayed target" setting.



2.4. Delayed target setting: (maximum target vacuum)

Press , to select, the value is higher than the value set by "evac target" or "off".

If "off" is selected, the "delay time" pressure maintaining time will default to "off", and skip directly to enter the sound setting.

2.5. Pressure maintaining time setting (delay time)

After the "delayed target" setting is completed, if the values of 3&4 are not "off", press enter to the setting of "delayed time". Press , to select. Then press to lock and stay on, then switch to the next parameter setting.

2.6. Sound setting "beep"

Press , to select, press to lock and then enter the next parameter "backlight" setting.

2.7. Backlight setting "B-L"

Press , to select, press to lock, it will return to the standby interface automatically.

3. Evacuation and Pressure Maintaining Interface I**(Both evac target and Delayed target are not set to off)**

- 3.1. After the vacuum pumping starts, the actual measured vacuum reading keeps getting smaller. When it reaches the "evac target" setting value, the value such as "XXX" keeps flashing. Press (any key) to turn off flashing and stop the prompt.
- 3.2. When the actual measured vacuum reading is less than the "evac target" value and rises to this reading, the pressure maintaining time starts to count from 0. Until exiting this interface or complete pressure maintaining. (if the vacuum is less than the evac target value, time will be paused until the collected number is greater than evac target. Then continue timing. Press or to select evac target, delayed target, delayed time and rate.
- 3.3. When do decay testing, If the vacuum reading does not exceed the set value of delayed target. It displays "pass" until you press (any key) to stop flashing, exit the prompt and return to the main standby interface.

- 3.4. When do decay testing, if the vacuum reading gets larger, reaches and exceeds the set value of delayed target, the buzzer will alarm, and the word "FAIL" will flash until you press any key to stop flashing and exit the prompt, and return to the standby main interface.
- 3.5. If pressure holding time is set to "off", alarm will start after the vacuum value exceeds decayed target.

**4. Evacuation and Pressure Maintaining Interface II
(Evac target and Delayed target are set to off)**

- 4.1. Evac target is set to off and delayed target is not set to off when the real-time vacuum reduces, the prompt of delayed target value will not be triggered. The prompt of "fail" and "alarm tone" will be triggered only when the vacuum value increases to the delayed target value.
- 4.2. Evac target is set to non off and delayed target is set to off when the target vacuum reduces, the "alarm tone" beep of evac target value will be triggered. When the vacuum value increases, the "fail" alarm will not be triggered.
- 4.3. Both evaluation target and delayed target are set to off all alarm prompts will not be triggered.

5. Zero setting calibration

Under the atmosphere, press and hold + at same time for more than 2 seconds until the vacuum display area displays "-----", the full calibration is completed.

Warning

WARNING: Read all safety warning and instructions. Failure to follow the warnings and instructions may result in electric shock, fire and/or serious injury.

1. Do not dismantle, open or shred rechargeable Li-polymer battery pack.
2. Do not expose battery pack to heat or fire. Avoid storage in direct sunlight.
3. Do not short-circuit a battery pack.
4. When battery pack is not in use, keep it away from other metal objects, like paper clips, coins, keys, nails, screws or other small metal objects, that can make a connection from one terminal to another. Shorting the battery terminals together may cause burns or a fire.
5. Do not subject battery pack to mechanical shock.
6. In the event of a battery leaking, do not allow the liquid to come in contact with the skin or eyes. If contact has been made, wash the affected area with copious amounts of water and seek medical advice.
7. Seek medical advice immediately if a battery pack has been swallowed.
8. Do not use any battery pack which is not designed for use with the equipment.
9. Use only the battery pack in the application for which it was intended.
10. Do not use a battery pack or appliance that is damaged or modified. Damaged or modified batteries may exhibit unpredictable behavior resulting in fire, explosion or risk of injury.
11. Keep battery pack out of the reach of children.
12. Always purchase the correct battery for the equipment.
13. Keep battery pack clean and dry.
14. Wipe the battery pack terminals with a clean dry cloth if they become dirty.
15. Dispose of properly.
16. Follow all charging instructions and do not charge the battery pack or appliance outside of the temperature range specified in the instructions. Charging improperly or at temperatures outside of the specified range may damage the battery and increase the risk of fire.
17. Instructions regarding battery charging, information regarding ambient temperature range for battery use and storage, and the recommended ambient temperature range for charging system during charging.

Operating Temperature	Charge	32~104°F(0~40°C)
	Discharge	14~140°F(-10~60°C)
Storage Temperature	1 month	-4~140°F(-20~60°C)
	3 month	-4~113°F(-20~45°C)
	1 year	-4~77°F(-20~25°C)

18. Rechargeable battery pack need to be charged before use. Always refer to the equipment manual for proper charging instructions. Charge only with USB(Type C) not exceed 5V=2A.


Product Overview



Technical Specification

Model	NST1	NST2
Measurement range	-40~257°F (-40~125°C)	
Accuracy	±2.34°F (±1.3°C)	
Resolution	0.1	
Operating temperature	-40~80°C, 10~90%RH	
Battery	2 x AAA	
Sensor	Pt100(ITS-90)	
Unit Weight	0.35 lbs	

Screen Display



Indicator Light

Power on status: Green light blinks 3 times.

Rest state:

- (1) Entering or exiting function setting, green light flashes 3 times fast.
- (2) Normal function and successful Bluetooth connection, green light flashes slowly.
- (3) Normal function but Bluetooth is not connected, yellow light flashes slowly.
- (4) Low battery or hardware failure, red light flashes slowly.

Alarm



Over range:

- (1) When the measured temperature is greater than 125°C and less than 150°C, the temperature value is displayed in red and the buzzer sounds continuously at a frequency of 0.5S.
- (2) When the measuring temperature is less than -40°C or more than 150°C, the display will show "OL" and the buzzer will sound for a long time.

Hardware failure:

- (1) When the temperature sensor fails, "ERR.-" is displayed and the buzzer sounds continuously for 1 second.
- (2) When Bluetooth is faulty, the buzzer sounds continuously for 1 second.

Bluetooth Connection

The device will keep the Bluetooth broadcast status after powering on; if the device is not connected, "  " is blinking constantly; If the device is connected, "  " is always on.

Automatic Shutdown

When "APO" is turned on, the unit automatically shuts down if no key is pressed for 2 hours.

Key Function


Switch on/off: Press and hold the key for 2 seconds to turn on the power, press and hold the key for 3s to turn off the power after turning on the power.

Turn off and light up the screen: under the non-function selection state, press the key to switch back and forth between off and light up the screen.

Function Selection:

- (1) Quickly double-click the button to enter the function setting interface, the setting order is Auto Power Off, Bluetooth Switch and Temperature Unit in order.
- (2) Click the button to select function.

Exploded View




Spare Parts List

No.	Item	Qty
1	Master Clamp Handle	1
2	LCD	1
3	Toothed Block	1
4	Temperature Sensor	1
5	O-ring	1
6	Cover	1
7	Toothed Block	1
8	Spring	1
9	Nut	1
10	Sub Clamp Handle	1
11	Battery Cover Plate	1
12	AAA Battery	2
13	Retaining Stud	1
14	Battery Shrapnel	1
15	PCBA	1
16	Button	1

Guide for App Download & Connection

iOS

Search for "myNAVAC" in the app market.



Andriod

Search Google Mall for "myNAVAC".





Log In

Account Login: Internet connection is required, all data records are stored in the backend server.

Visitor Mode: No internet connection is required, all data records are stored locally on the cell phone.

Page Introduction



Basic Functions

Link Device

Turn on your phone's Bluetooth. In the main interface, tap the plus button in the lower right corner to search available devices.

(Note: If you are using the NX1 with a vacuum gauge and temperature probes, please connect the vacuum gauge and temperature probes to the NX1 first, and then connect the NX1 to the APP).



Find the target device you need to connect to, click the plus sign in the upper right corner and wait for the connection to be established.



If the connection is successfully established, it will automatically jump to the main interface, click the device icon to enter the device interface.



Data logging

Click "●" in the bottom navigation bar to turn on the data logging function. Click Start to record data.



Click again on the bottom navigation bar "●", to save or restart the record. Then select a Job you wish to save to.



Basic Functions

View Test Report

Click "📄" in the bottom navigation bar on the device page to view the test report on the current device.



On the main page, click "Job" in the bottom navigation bar to view the test reports saved in the workbook.




On the main page, click "Test Report" on the bottom navigation bar to view the test reports of all devices.



Share Test Reports

Press the "Share" button at the bottom of the test report, a pop-up window will prompt you to select the the file type and interval for the test report format.



After determining the the file type and interval, a data table will be automatically generated, click "📄" in the upper right corner to share the test report.

