

NSV1 Smart Refrigerant Valve

User Manual



A

Failure to follow warnings could result in death or serious injury.

SAVETHIS MANUAL FOR FUTURE REFERENCE

NAVAC Inc. www.NavacGlobal.com Tel/Fax: +1 877 MY-NAVAC 877 696 2822

MADE IN PRC

CONTENTS

I. Safety Instructions	01
II. Technical Specification	03
III. Product Overview	04
IV. Structural Breakdown Diagram	05
V. System Connection Diagram	08
VI. Page Introduction	09



Warning

This product contains a built-in lithium-ion battery.

- Do not disassemble, puncture, crush, or expose the battery to fire, high temperatures, or water.
- Use only the provided or compatible charger specified in the manual.
- Improper handling of the battery may cause fire, explosion, or serious injury.
- · Dispose of the product following local regulations. Do not dispose of it with household waste.

I. Safety Information

Please read this manual carefully before operating, overhauling, or maintaining the product in order to fully understand the safety issues and precautions necessary for its proper use and operation to ensure long-term, stable operation.

Please carefully verify that the product you received matches your order, that all accessories and the instruction manual are complete, and that there is no damage from transportation. If you find any of the above situations, please contact customer service or local distributor promptly.

By carefully reading the manual and adopting the correct operation, you can ensure both the safe operation and the service life of this equipment.

Dispose of This Product Correctly



This mark indicates that this product should not be disposed of with other household waste. It is important to prevent uncontrolled waste disposal that may be harmful to the environment or human health, please use a



return and collection system or contact the retailer from whom you purchased the product. They can recycle this product in an environmentally safe manner.



Warning

Indicates a risk of injury or death if used incorrectly.



Indicates improper use may cause damage to the equipment, preventing it from operating properly or reducing its performance.



Warning

- This equipment must be operated by qualified personnel who are familiar with air conditioning and refrigeration systems!
- 2. All components (system, refrigerant meter valve group, refrigerant cylinder, etc.) should be properly and securely grounded before starting this equipment!
- Please open the equipment to check whether the sealing is proper before using it to prevent refrigerant leaks that could pose a risk to personnel!
- 4. Please wear protective gloves and goggles during operation to prevent the refrigerant from coming into contact with your skin or eyes and causing harm to your health!
- 5. 5. Connect the tubes of this equipment according to the instructions to prevent the wrong connection that could lead to refrigerant leaks and harm to personnel!
- 6. The product shall not be used in a potentially explosive environment!

▲ Caution

- Please open the equipment before use to check whether the power is sufficient or not!
- Please check the equipment before use to ensure that the metal valve opens and closes normally!
- Please check the equipment before use to ensure that the sealing of the metal valve is functioning properly!
- 4. Please screw the copper cap on the inlet and exhaust joints after using the equipment!
- 5. After completing the charging process, the refrigerant flow in the refrigerant cylinder should be stopped!
- The smart solenoid valve shall not be used near a magnetic field!

II. Technical Specification

Environmental Conditions	Operating temperature: -10 ~ 50 °C / 14 ~122 °F Storage temperature: -10 ~ 50 °C / 14 ~122 °F Humidity in the operating area: 1090 % RH			
	Class III: R12, R134a, R401C, R406A, R500			
Applicable Refrigerant	Class IV: R22, R401A, R401B, R402B, R407C, R407D, R408A, R409A, R502, R509			
	Class V: R143A, R402A, R404A, R407A, R407B, R410A, R507			
Power Supply	Power: Battery pack rated at 7.4v DC (rechargeable) Battery pack life: > 60 h with 2000 cycles of solenoid valve operation			
Interface	2.4Ghz support BLE5.0 Bluetooth transmitting module			
Maximum Operating Pressure	551 psi			
Bluetooth Range	100 ft (30m) line of sight			
Protection Class	IP54			
Dimensions	4.76"H × 3.62"W × 1.87"D			
Net weight	1.33 lbs			





III. Product Overview




- 1. Folding Hook
- 2. Charging Port
- 3 Power Indicator

Power indicator					
	Power Indicator				
•	Red indicates charging				
•	Green indicates charging fully charged				
	Flashing green 25% <power td="" ≤100%<=""></power>				
	Flashing yellow 5% <power td="" ≤25%<=""></power>				
۱	Flashing red power ≤5%				

- 4. Bluetooth indicator: Shows the Bluetooth status of the device.
- Flashing yellow: Bluetooth is not connected (standby mode).
- · Flashing blue: Bluetooth connected.
- · Flashing red: Bluetooth module error.
- Valve indicator: Indicates the device's valve status.
- Always green: Open valve.
- Off: Closed valve.
- · Flashing red: Abnormal.
- 6. Operation buttons: Control the device's power and manage the opening and closing of the metal valve.
 - Turn on the device: Press and hold the button for 2 seconds.
 - Turn off the device: Press and hold the button for 2 seconds.
 - Open the valve: Press the button twice within 0.3 seconds while the device is on.
 The valve will open for 1 second before closing.
 - Close the valve: Press the button while the valve is open to close it instantly.
- 7. Refrigerant input port: 1/4" SAE.
- 8. Refrigerant output port: 1/4" SAE.





Snare Parts List

Spare Parts List				
No.	Item			
1	Cross Recessed Pan Head Tapping Screws			
2	Electromagnetic Cover			
3	Lithium Battery Pack			
4	Cross Recessed Countersunk Head Tapping Screws			
5	Hook Pressure Plate			
6	O-Ring			
7	Hook			
8	O-Ring			
9	Lower Housing			
10	Cross Recessed Pan Head Tapping Screws			
11	O-Ring			
12	Copper Cap Assembly			
13	Strainer Press Studs			
14	Strainer			
15	Self-retaining Valve			
16	Cross Recessed Countersunk Head Tapping Screws			
17	Compression Caps			
18	PCB Assembly			
19	Upper Housing			
20	Pushbutton			
21	Plug			

06 07




V. System Connection Diagram

Solution 1



Solution 2



VI. Page Introduction

Main Interface:





Setup Interface:

